



Join to Existing Cleaned & Lined 6IN CI

160mm HPPE 10Bar Electrofusion fittings

Install New 80mm SV

Join to Existing Cleaned & Lined 3IN CI

160mm HPPE 10Bar Electrofusion fittings

Thrust Block D

Existing 6IN CI to be Abandoned & Capped Off

Existing 6IN CI to be Abandoned & Capped Off

Thrust Block B

Connect to Existing PRV Inlet to PRV = 18 Bar

Existing 6IN CI to be Abandoned & Capped Off

Existing 3IN CI - Cleaned & Lined

PRV

Thrust Block B

New 150mm DIEL 25Bar NP25 Rated Fittings required on Inlet of PRV

160mm HPPE 10Bar Electrofusion fittings

Thrust Block C

Install New 80mm SV

90mm HPPE 10Bar Electrofusion fittings

Recently laid 150mm DIEL

Thrust Block A

Recently laid 150mm DIEL